

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

Inspection report emailed to Manuel Ruiz on 09/16/2024.

At the time of inspection no showers onsite were observed.

Email Address(es): maruiz@dadeschools.net;
mwertz@dadeschools.net;
ipalacio@dadeschools.net;
wcabrera@dadeschools.net

Violations Comments

Violation #5. Maintenance & Repair

Observed missing ceiling tiles caused by roof leak at classrooms D1 and D5. Roof leak was repaired. Replace / install ceiling tiles.

Observed uneven hallway floor in front on classroom D1, which can be a safety hazard. Repair hallway floor.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #6. Lighting Standards

Observed burned lights at classrooms :D1, D2, D3 and D4, 29 foot candles were recorded. Repair lights to get minimum 40 foot candles of light.

CODE REFERENCE: 6. Lighting Standards. 468.3.2. FBC. Sources of natural light in instructional spaces shall be glazed with glare reducing materials or shall be shielded to prevent glare that can interfere with seeing task.

Inspection Conducted By: Cesar Martinez (085423)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: Manuel Ruiz
Date: 9/16/2024

Inspector Signature:

CM

Client Signature:

Manuel Ruiz